## **OMNI ENERGY GENERATOR PP 44**



## **Technical Specifications**

MACHINE SPECIFICATION		
Genset Model	PP 44	
Power Rating Prime *	40 kVA	
Power Rating Stand By **	44 kVA	
Alternator Model	SLG 224C	
Control Panel Model	Digital M <mark>odule</mark> Type (Deep Se <mark>a DSE</mark> 720)	
Frequency / Voltage	50 Hz / 3 <mark>80-41</mark> 5 V	
Fuel Tank Capacity	8-10 Hours	
Fuel Consumption (L/h max		
load)	8.5	
ENGINE SPECIFICATION		
Engine Model	ATS 441 GN	
Engine Type	4 - Stroke Diesel	
Cylinder (No &		
Arrangement)	3-Vertical in Line	
Bore / Stroke	101/127 mm	
Aspiration	Naturally Asp	
Cooling System	Water Cooled	
Governor	Mechanical Type	
Electronic System	12 Volt	
ALTERNATOR DATA		
No of Bearings	Single Bearing	
Wires	4-Wires	
Insulation Class	Н	
Ingress Protection Rating	IP 23	
Voltage Regulation	±2%	

DIMENSIONS		
Le	ngth	200 cm
W	idth	121 cm
He	eight	161 cm
W	eight	1000 kg

## **OPTIONS**

- \* Acoustic and Weather Canopies
- \* Auto Start with Auto transfer Switch Panel
- \* Manual Over-Ride System
- **Extra Storage Tanks**
- \* 2/4 Wheels Trailer mounted
- \*Prime Rating: These ratings are applicable for supplying continuous electrical power (at variable load) in lieu of commercially purchased power. There is no limitation to the annual hours of operation and this model can supply 10% overload power for 1 hour in 12 hours.
- \*\*Standby Rating: These ratings are applicable for supplying continuous electrical power (at variable load) in the event of a utility power failure. No overload is permitted on these ratings.

The above performance data is valid as per the following specs:

- \* Diesel fuel is according to BS2869 class or equivalent
- Lubricating oil is according to API CG4 (15W/40) or higher
- \* The coolant should be 50% antifreeze and 50% distilled water